



LAB N° 0073

RAPPORTO DI PROVA / TEST REPORT N. 124850

page 1 of 2

Marghera

13/02/2015

rif. Your email of November 11th, 2014

richiedente
proposer

NEDEX KIMYA SAN.VE.TIC.A.S. - CETIN CADDESI KIZ KALESI
SOKAK No:1 ELIT PLAZA - 34775 UMRANIYE (ISTANBUL)

campione
sample

sealant membranes

prova eseguita dal / from 18/12/2014
test date al / to 5/02/2015

contrassegnato
reference

PS 545 R

ricevuto il
received

14/11/2014 by carrier

MVTRing r3 25/8/2011

Moisture vapour transmission rate on a film according to prEN 1279-4: October 2014

Producer: Nedex
Product type: polysulphide
(chemical family)
Denomination: PS 545 R
Sampling: carried out by the proposer
Test carried out at: Marghera laboratories

The moisture vapour permeability of the sealing membranes supplied by you was measured according to prEN 1279-4: October 2014 "Glass in Building – Insulating Glass Units – Part 4: Methods of test for the physical attributes of edge seal components and inserts" Annex D on 3 different specimens labelled by our laboratory as 1, 2, and 3. Each specimen underwent repeated measurements in different days.

The test specimens were prepared as follows: membranes were placed (as hermetic seal) on a glass dish containing about 30 grams of molecular sieves with an initial water content of 1,0%. Under these test conditions the passage of moisture vapour to the outside could occur only through the membrane itself.

The three dishes prepared with each sample membrane were weighed and placed in a climatic chamber with forced ventilation at 23°C and 90% relative humidity. Weighing was repeated at few-days intervals in order to determine the MVTR (Moisture Vapour Transmission Rate).

*Le prove riportate in questo rapporto contrassegnate dalla dicitura ** Non Accreditata da ACCREDIA ** non rientrano nell'Accreditamento ACCREDIA di questo Laboratorio. Si attesta che il campione oggetto di analisi esibito dalla ditta richiedente presenta le caratteristiche sopra riportate. Il presente attestato si riferisce al campione esaminato e non può essere riprodotto parzialmente. In carta semplice per gli usi consentiti dalla legge.*

The tests indicated in this report which are cited as ** Non Accredited by ACCREDIA ** do not fall under ACCREDIA Accreditation. We declare that the analysed sample, provided by the customer, presents the above-mentioned characteristics. This Test Report is relevant exclusively for the specimen tested and it cannot be partially reproduced. Issued on unstamped paper for the uses foreseen by the law.



RAPPORTO DI PROVA / TEST REPORT N. 124850

page 2 of 2

Marghera

13/02/2015

rif. Your email of November 11th, 2014

richiedente
proposer

NEDEX KIMYA SAN.VE.TIC.A.S. - CETIN CADDESI KIZ KALESI
SOKAK No:1 ELIT PLAZA - 34775 UMRANIYE (ISTANBUL)

campione
sample

sealant membranes

prova eseguita dal / from 18/12/2014
test date al / to 5/02/2015

contrassegnato
reference

PS 545 R

ricevuto il
received

14/11/2014 by carrier

MVTRing r.3 25/8/2011

The results obtained for three samples are reported in the following table:

time (in days)	Weight increase (in grams)		
	sample n° 1	sample n° 2	sample n° 3
13	0.436	0.451	0.498
20	0.740	0.761	0.828
28	1.068	1.090	1.173
35	1.360	1.374	1.482
42	1.625	1.637	1.768
49	1.907	1.922	2.068
Membrane thickness(in mm)	2.4	2.3	2.2
Dish mouth area (in m ²)	0.00785	0.00785	0.00785
MVTR	5.2	5.2	5.5
MVTR calculated for 2 mm (*)	6.2	6.0	6.1

Average MVTR calculated for 2 mm (*): $6.1 \pm 0.1 \frac{\text{grams H}_2\text{O}}{\text{m}^2 \cdot 24 \text{ h} \cdot 2 \text{ mm}}$

(*) An inverse relationship between thickness and permeability was assumed in the calculation.

Attachments: n° 3 graphs


IL RESPONSABILE DEL LABORATORIO
Ennio Mognato

THE LABORATORIES DIRECTOR
Dr. Nicola Favaro


*Le prove riportate in questo rapporto contrassegnate dalla dicitura ** Non Accreditata da ACCREDIA ** non rientrano nell'Accreditamento ACCREDIA di questo Laboratorio. Si attesta che il campione oggetto di analisi esibito dalla ditta richiedente presenta le caratteristiche sopra riportate. Il presente attestato si riferisce al campione esaminato e non può essere riprodotto parzialmente. In carta semplice per gli usi consentiti dalla legge.*

*The tests indicated in this report which are cited as ** Non Accredited by ACCREDIA ** do not fall under ACCREDIA Accreditation. We declare that the analysed sample, provided by the customer, presents the above-mentioned characteristics. This Test Report is relevant exclusively for the specimen tested and it cannot be partially reproduced. Issued on unstamped paper for the uses foreseen by the law.*

Sample n° 1



Sample n° 2



Sample n° 3

